

MAINTENANCE CHECK LIST

Inspect general operating condition of the unit weekly by checking for unusual vibration, sound or feel (such as an overheated motor), and proper bleed-valve setting.

Procedure	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
△ Clean Basin (Monthly)												
Check Operating Water Level (As Required)												
Check Water Distribution (Quarterly)												
Check Belt Tension (Monthly)												
Clean Air Inlet Screens (As Required)												
Lubricate Fan Shaft Bearings (Every 3 Months)												
Clean and Touch Up Protective Finish (Once a Year)												
Flush Out Spray Headers (Once a Year)												
Check Bleed-Valve Setting (Weekly)												

△ WARNING **Cooling Tower Cleaning:**
Any evaporative-type cooling tower must be thoroughly cleaned on a regular basis to minimize the growth of bacteria, including Legionella Pneumophila, to avoid the risk of sickness or death. Service personnel must wear proper personal protective equipment. Do NOT attempt any service unless the fan motor is locked out.

Lubricant Recommendations
 Mobil shc 460

